

PRODUCT CERTIFICATE OF REGISTRATION



Global Certification Pty Ltd

Number 582

AS/NZS 1546.1:2008

Issued to

Access Septic Products Pty Ltd

Tenancy 4, 1 Sherriffs Road West Lonsdale S.A. 5160

Certification Date: - 18 November 2020 Expiry Date: - 17 November 2025

Product Certified:

Tank Type	Description	Total Size	Additional Product Information	Manufacture & Assembly Sites
Collection well/ holding tank	Fibreglass horizontal cylinder: DN1500mm;22.9mm thick. Tanks can contain baffles if required.	3500 Ltr	Access Holding Tank 35	Manufactured and assembled Tenancy 4, 1 Sherriffs Road West Lonsdale S.A. 5160
		4000 Ltr	Access Holding Tank 40	
Collection well/ holding tank	Fibreglass horizontal cylinder: DN1600mm;24.3mm thick. "6 bar" pressure class or higher Tanks can contain baffles if required.	5000 Ltr	Access Holding Tank 50	
Septic Tank	Fibreglass horizontal cylinder: DN1500mm;22.9mm thick. Tanks can contain baffles if required.	3500 Ltr	Access Septic 35, (actual capacity 3978 Ltr available capacity 3600 Ltr)	
		4000 Ltr	Access Septic 40, (actual capacity 4425 Ltr available capacity 4005 Ltr)	
Septic Tank	Fibreglass horizontal cylinder: DN1600mm;24.3mm thick. "6 bar" pressure class or higher Tanks can contain baffles if required.	5000 Ltr	Access Septic 50, (actual capacity 5594 Ltr available capacity 5100 Ltr)	

This Certificate of Conformance to the Product Certificate Scheme for "Domestic Wastewater Treatment Units (Septic Tanks) and Rainwater Tanks" remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.

Date of Issue: 18th November 2020


Bruce Smith Director



JAS-ANZ



www.jas-anz.com.au/register

Signed for and on behalf of Global Certification Pty Ltd
PO Box 953 Belconnen ACT 2616